



**NOTES:**

1. A commercial driveway is defined as a driveway that serves a commercial, manufacturing, or industrial facility, or more than four (4) residences.
2. Concrete shall be Class 520-C-2500 (5½ sack min., ¾" aggregate)
3. The minimum allowable driveway width shall be 12'.
4. The maximum allowable driveway width shall be less than 36% (36' max.) unless otherwise approved by the City Engineer.
5. Refer to Standard Plan 111-AG for curb ramp details.
6. Compacted base shall extend 6" beyond perimeter of driveway.
7. Concrete shall receive light broom finish perpendicular to vehicular direction and Type II - white pigmented sealing and curing compound.
8. Compacted Class II aggregate base, 6" min. depth. (Min. R value = 75, SE = 55).

**REFERENCE:**

- 112-AG Curb and Sidewalk Joints
- 114-AG Driveway Location
- 115-AG Detached and Integral Sidewalk
- 120-AG Curb and Gutter Barrier

CITY OF ARROYO GRANDE - ENGINEERING DEPARTMENT

STANDARD PLAN

ISSUE DATE:  
APR 1, 2005

**DRIVEWAY APPROACH  
COMMERCIAL**

Don Spagnolo, P.E.  
Director of Public Works/City Engineer  
L.C.E. No. 42993

**110-AG**